Test Report issued under the responsibility of:





TEST REPORT IEC 62368-1

Audio/video, information and communication technology equipment Part 1: Safety requirements

Report Number:	E252373-A6034-CB-1
Date of issue:	2022-09-20
Total number of pages	80
Name of Testing Laboratory	UL International-Singapore Pte Ltd
preparing the Report	20 Kian Teck Lane, Singapore 627854, Singapore
Applicant's name:	TDK-LAMBDA SINGAPORE PTE LTD
Address:	#06-01/08
	1008 TOA PAYOH NORTH
	SINGAPORE 318996 SINGAPORE
Test specification:	
Standard	IEC 62368-1: 2018
Test procedure:	CB Scheme
Non-standard test method:	N/A
TRF template used	IECEE OD-2020-F1:2020, Ed.1.3
Test Report Form No	IEC62368_1E
Test Report Form(s) Originator:	UL(US)
Master TRF	Dated 2021-02-04
Copyright © 2021 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and	

Copyright © 2021 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.

Test Item Description:	Switching Power Supply
Trade Mark(s):	
	TDK·Lambda
Manufacturer:	TDK-LAMBDA SINGAPORE PTE LTD
	#06-01/08
	1008 TOA PAYOH NORTH
	SINGAPORE 318996 SINGAPORE
Model/Type reference:	DRB120-24-1wxyz, DRB120-24-1/RYwxyz, DRJ120-24-1wxyz, and DRJ120-24-1/Ewxyz
	where w,x,y,z are considered as non safety related information:
	w can be "-" or "/" or blank or any alphanumeric;
	x can be CO or CO2 or blank or any alphanumeric;
	y can be blank or any alphanumeric;
	z can be blank or any alphanumeric;
Ratings:	Input: 100-240 VAC, 1.5 A, 50/60 Hz.
	Output: 24-28 Vdc, 5-4.3A. Maximum power: 120W

Responsible Testing Laboratory (as applicable), testing procedure and testing location(s):		
CB Testing Laboratory:		
Testing location/ address:	UL International-Singapore Singapore 627854, Singap	e Pte Ltd, 20 Kian Teck Lane, bore
Tested by (name, function, signature):	Zheng Yan Tan / Project Handler	Zheng Yan
Approved by (name, function, signature) :	Ming Yuo Chai / Reviewer	MingYuo
	·	
Testing procedure: CTF Stage 1:		
Testing location/ address:		
Tested by (name, function, signature):		
Approved by (name, function, signature) :		
Testing procedure: CTF Stage 2:		
Testing location/ address:		
Tested by (name, function, signature):		

Witn	essed by (name, function, signature).:		
Approved by (name, function, signature) :			
	Testing procedure: CTF Stage 3:		
	Testing procedure: CTF Stage 4:		
Test	ing location/ address		
Test	ed by (name, function, signature):		
Witn	essed by (name, function, signature) . :		
Арр	roved by (name, function, signature) :		
Sup	ervised by (name, function, signature) :		

National Differences (28 pages) Enclosures (33 pages)	
Summary of testing:	
Tests performed (name of test and test clause):	Testing Location:
	CBTL: UL International-Singapore Pte Ltd, 20 Kian Teck Lane, Singapore 627854, Singapore
4.4.3.2, T.3 – STEADY FORCE TEST, 30 N FOR SAFEGUARD THAT ACTS AS FIRE ENCLOSURE/BARRIER ONLY	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
4.4.3.8, T.8 – STRESS RELIEF TEST	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
5.2.2.1-5.2.2.6 – CLASSIFICATION OF ELECTRICAL ENERGY SOURCES	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
5.4.1.8 – DETERMINATION OF WORKING VOLTAGE	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
5.4.1.10.3 – BALL PRESSURE TEST	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
5.4.9.1 – ELECTRIC STRENGTH TEST – TYPE TESTING OF SOLID INSULATION	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
5.5.2.2 – CAPACITOR DISCHARGE AFTER DISCONNECTION OF A CONNECTOR	
5.6.6.2 – RESISTANCE OF THE PROTECTIVE BONDING SYSTEM	
5.7.4 – TOUCH VOLTAGE AND TOUCH CURRENT MEASUREMENT – UNEARTHED ACCESSIBLE PARTS	
5.7.5 – TOUCH CURRENT MEASUREMENT – EARTHED ACCESSIBLE CONDUCTIVE PARTS – SINGLE-PHASE EQUIPMENT ON TN OR TT SYSTEM	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
B.2.5 – INPUT TEST: SINGLE PHASE	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
B.2.6, 5.4.1.4, 6.3, 9.3, B.1.5 – NORMAL OPERATING CONDITIONS TEMPERATURE MEASUREMENT	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
B.3 – SIMULATED ABNORMAL OPERATING CONDITIONS	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
B.4 – SIMULATED SINGLE FAULT CONDITIONS	Conducted during CBTR Ref. No.: E252373-A6004-CB-1 issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.

F.3.10 – TEST FOR THE PERMANENCE OF MARKINGS	Conducted during CBTR Ref. No.: E252373-A6004-CB-1, issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.
G.5.3.3 – TRANSFORMER OVERLOAD	Conducted during CBTR Ref. No.: E252373-A6004-CB-1, issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02 investigation.

Summary of compliance with National Differences (List of countries addressed):

EU Group and National Differences, USA / Canada

The product fulfils the requirements of EN IEC 62368-1:2020+A11:2020, BS EN IEC 62368-1:2020+A11:2020

Additional Country Information:

Singapore (National Differences as provided on IECEE Website. TRF is included in Enclosure ID 07-04 of this test report),

United Kingdom (per customer's request shown separately)

Statement concerning the uncertainty of the measurement systems used for the tests


Internal procedure used for type testing through which traceability of the measuring uncertainty has been established:

Procedure number, issue date and title:

Calculations leading to the reported values are on file with the NCB and testing laboratory that conducted the testing.

Statement not required by the standard used for type testing

(Note: When IEC or ISO standard requires a statement concerning the uncertainty of the measurement systems used for tests, this should be reported above. The informative text in parenthesis should be delete in both cases after selecting the applicable option)



Test item particulars:		
Product group	built-in component	
Classification of use by	Ordinary person	
Supply Connection	AC Mains	
Supply tolerance	+ 10 % / - 15 %	
Supply connection – type	Terminal Block for internal connection within end product	
Considered current rating of protective device	16 A (for countries other than Canada and USA); 20 A (for Canada and USA); A; Location: building	
Equipment mobility	for building-in	
Over voltage category (OVC)	OVC II	
Class of equipment	Class I	
Special installation location	N/A	
Pollution degree (PD)	PD 2	
Manufacturer's specified Tma (°C)	Up to 70 °C, which depend on mounting direction and load factor. (See Enclosure ID 07-01 for details.)	
IP protection class	IPX0	
Power systems	TN IT - 230 (For Norway) V L-L	
Altitude during operation (m)	3000 m	
Altitude of test laboratory (m)	2000 m or less	
Mass of equipment (kg)	0.45	
Possible test case verdicts:		
 test case does not apply to the test object: 	N/A	
 test object does meet the requirement 	P (Pass)	
- test object does not meet the requirement:	F (Fail)	
Testing:		
Date of receipt of test item:	2022-08-02	
Date (s) of performance of tests:	2022-09-13 to 2022-09-14	
General remarks:		
"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report.		
Throughout this report a \Box comma / $igtriangleq$ point is used as the decimal separator.		

Manufacturer's Declaration per sub-clause 4.2.5 of IECEE 02:

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided	 ☑ Yes ☑ Not applicable
When differences exist; they shall be identified in th	e General product information section.
Name and address of factory (ies) :	PANYU TRIO MICROTRONICS CO LTD SHIJI INDUSTRIAL ESTATE DONGYONG NANSHA GUANGZHOU GUANGDONG 511453 CHINA TDK-LAMBDA MALAYSIA SDN BHD LOT 2 & 3, BATU 9 3/4 KAWASAN PERINDUSTRIAN BANDAR BARU JAYA GADING 26070 KUANTAN PAHANG MALAYSIA SDN BHD
	PLO33 KAWASAN PERINDUSTRIAN SENAI
Concrete product information and other remarks:	81400 SENAI JOHOR MALAYSIA

General product information and other remarks:

Product Description

The product covered in this report is a building-in component switch-mode power supply (DIN rail type).

Model Differences

Model DRB120-24-1/RY:

Identical to model DRB120-24-1 except for photo coupler (PC200) which interfacing external control circuit is replaced by photo MOS.

Model DRJ120-24-1:

Identical to model DRB120-24-1 except for Input and Output terminal blocks type, and Input Board and Output Board PCB trace design respectively.

Model DRJ120-24-1/E:

Identical to model DRB120-24-1 except for Input and Output terminal blocks type, and Input Board and Output Board PCB trace design respectively.

Model / Input and Output PCB Drawing No. / Terminal Block Cat. No.

DRB120-24-1/ SCB479A / Euro Type by DECA Switchlab.

DRJ120-24-1/ SCB489A / Screw type by Emuden Corp.

DRJ120-24-1/E / SCB488 / Screwless type by Tianli Electrical Machinery (NingBo) Co., Ltd.

Models with suffix, CO: Model with optional thin coating (QMJU2) on one side of PWB. Models with suffix, CO2: Model with optional thin coating (QMJU2) on both sides of PWB.

Rating label designs are identical except for model name.

Additional Information

Rated output condition for testing:

Test load condition A: 24 Vdc, 5A.

Test load condition B: 28 Vdc, 4.3A.

Unless otherwise noted, all tests were conducted on model DRB120-24-1 as representative of all models in this report.

Manufacturer has simulated end-product loading condition to power supply 144 W for 10 seconds and resting time18.6 seconds at 105.6 W, which equals total r.m.s. power 119.8 W. Refer Enclosure ID 07-03 for details.

This report is issued due to the following:

- standard upgrade IEC 62368-1:2018;

- additional alternate X-Capacitor (C3), Mfr: TDK (Zhuhai FTZ) Co., Ltd., Type: B3292, Mfr: PANASONIC CORPORATION, PANASONIC CORPORATION OF NORTH AMERICA, Type: ECQUA or ECQUL, Mfr: OKAYA ELECTRIC INDUSTRIES CO LTD, Type: LE or LE-xx series and Mfr: Europtronic (SuZhou) Co. Ltd., Type: MPX2;

- removed alternate X-Capacitor (C3), Mfr: Europtronic (Taiwan) Industrial Corp., Type: MPX2;

- additional alternate X-Capacitor (C6), Mfr: TDK (Zhuhai FTZ) Co., Ltd., Type: B3292, Mfr: PANASONIC CORPORATION, PANASONIC CORPORATION OF NORTH AMERICA, Type: ECQUA or ECQUL and Mfr: OKAYA ELECTRIC INDUSTRIES CO LTD, Type: LE or LE-xx series;

- additional alternate Y-Capacitor (C1, C2, C4, C5), Mfr: MURATA MFG CO LTD, Type: RA, Mfr: TDK CORPORATION, Type: CD and Mfr: WALSIN TECHNOLOGY CORP, Type: AH;

This test report is based from CBTR Ref. No.: E252373-A6004-CB-1, issued date 2018-08-01, with CBTC No. DK-75411-UL, issued date 2018-08-02.

Based on previously conducted testing and the review of the product construction, only limited test were deemed necessary.

Technical Considerations

- The product was submitted and evaluated for use at the maximum ambient temperature (Tma) permitted by the manufacturer's specification of : Up to 70 °C, which depend on mounting direction and load factor. (See Enclosed Id. 7-01 for details.)
- The product is intended for use on the following power systems : IT, TN
- Considered current rating of protective device as part of the building installation (A) : 20
- Mains supply tolerance (%) or absolute mains supply : +10%/-15%
- The equipment disconnect device is considered to be : Provided in end product

Page 10 of 80

Engineering Conditions of Acceptability

When installed in an end-product, consideration must be given to the following:

- The following product-line tests are conducted for this product : Electric Strength
- The end-product Electric Strength Test is to be based upon a maximum working voltage of : 418 Vpk, 250 Vrms
- The following output circuits are at ES1 energy levels : Output
- The following output circuits are at PS3 energy levels : Output
- The maximum investigated branch circuit rating is : 20 A
- The investigated Pollution Degree is : 2
- Proper bonding to the end-product main protective earthing termination is : Required (Chassis)
- The following end-product enclosures are required : Electrical, Fire
- The following magnetic devices (e.g. transformers or inductor) are provided with an OBJY2 insulation system with the indicated rating greater than Class A (105°C) : T1, L3 (Class 155(F))
- Line to Line Capacitor (C3, C6) may have variation in capacitance up to 1.0 uF. Therefore, consideration shall be given in controlling the capacitance value in the end-product application with respect to capacitance discharge issue.
- Primary to Ground Capacitor (C1, C2) may have variations in capacitance up to 1000pF. Therefore, consideration shall be given in controlling the capacitance values in end product application with respect to touch Current issue.
- Primary to Ground Capacitor (C4, C7, C8) may have variations in capacitance up to 2200pF. Therefore, consideration shall be given in controlling the capacitance values in end product application with respect to touch Current issue.
- Humidity conditioning has been conducted by tropical condition.
- Classification of PIS has not been conducted. Therefore, all electrical components and conductors including printed wirings were assumed to be arcing/resistive PIS.
- This component has been evaluated in 'control of fire spread' method assuming appropriate fire enclosure is provided in end product. Unless the fire enclosure is made of non-combustible or V-0 material, the separation from the PIS shall be considered.
- Varistor was not tested overload per Annex G.8.2.2, end product shall consider the use of enclosure made by metal or keep a distance of minimum 13mm from Varistor when use of enclosure made of combustible material. Otherwise varistor shall additional perform overload test according to Annex G.8.2.2