



Ref. Certif. No.

DK-127302-A1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-mode Power Supply
Name and address of the applicant	TDK-LAMBDA UK LTD KINGSLEY AVE ILFRACOMBE EX34 8ES United Kingdom
Name and address of the manufacturer	TDK-LAMBDA UK LTD KINGSLEY AVE ILFRACOMBE EX34 8ES United Kingdom
Name and address of the factory	TDK-LAMBDA UK LTD KINGSLEY AVE ILFRACOMBE EX34 8ES United Kingdom
Note: <i>When more than one factory, please report on page 2</i>	Additional Information on page 2
Ratings and principal characteristics	zMU4FSDdef-ghi, zMU4FSEdef-ghi Input: 100-240Vac nom, 8A rms max, 47-440Hz, Output: 600W 200-240Vac nom, 6A rms max, 47-440Hz, Output: 800W Additional Information on page 2
Trademark (if any)	 TDK-Lambda
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	zMU4FSEdef-ghi, zMU4FSFdef-ghi, zMU4FSGdef-ghi, zMU4FSDdef-ghi Additional Information on page 2
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to: EN 60950-1:2006, EN 60950-1:2006/A1:2010, EN 60950-1:2006/A2:2013, EN 60950-1:2006/A11:2009 The report was revised to include administrative modifications. Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60950-1:2005/AMD1:2009, IEC 60950-1:2005/AMD2:2013, IEC 60950-1:2005
As shown in the Test Report Ref. No. which forms part of this Certificate	E135494-A6053-CB-1 issued on 2022-08-01

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-08-01
Original Issue Date: 2022-05-09

Signature: Jan-Erik Storgaard



Ref. Certif. No.

DK-127302-A1-UL

Factory(ies):

Panyu Trio Microtronics Co Ltd
SHIJI INDUSTRIAL ESTATE
DONGYONG
NANSHA GUANGZHOU, GUANGDONG, 511453
China

Additional Model Detail(s):

MU series: zMU4FSEdef-ghi, **MU series:** zMU4FSFdef-ghi, **MU series:** zMU4FSGdef-ghi, **MU series:** zMU4FSDdef-ghi, Where z may be blank or NS # followed by / or - (where # may be any number of characters), or SP followed by / or -, d may be L or R, e may be blank or E5H or T5H or Q5xxxxx (where x may be any number or letter), f may be CO or Cox or blank, May be followed by -ghi where ghi may be any 3 characters. Refer to Model Differences section in the Test Report for details.”

Additional Ratings:

zMU4FSFdef-ghi, zMU4FSGdef-ghi
input: 144-318Vdc nom, 6A dc max, Output: 600W
278-318Vdc nom, 4.1A dc max, Output: 800W

Additionally evaluated to:

EN 60950-1:2006/A12:2011

Summary of Modifications:

model description and nomenclature revised. See test report for details.

Additional information (if necessary)




- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-08-01
Original Issue Date: 2022-05-09

Signature:


Jan-Erik Storgaard